

## Environmental Noise Analysis

# North Summit Cellular Facility

Santa Cruz County, California

BAC Job # 2014-230


Prepared For:

Complete Wireless Consulting

Attn: Kim Le  
2009 V Street  
Sacramento, CA 95818

Prepared By:

**Bollard Acoustical Consultants, Inc.**



Paul Bollard, President

December 16, 2015



## Introduction

The North Summit Verizon Wireless Unmanned Telecommunications Facility Project (project) proposes the construction of a monopine cell tower and the installation of outdoor equipment cabinets and an emergency diesel standby generator inside a fenced area located approximately 260 feet south of Loma Prieta Avenue in Los Gatos (Santa Cruz County), California. The outdoor equipment cabinets and the emergency diesel standby generator have been identified as primary noise sources associated with the project. Please see Figure 1 for the general site location. The studied site design is dated September 15, 2015.

Bollard Acoustical Consultants, Inc. has been contracted by Complete Wireless Consulting, Inc. to complete an environmental noise assessment regarding the proposed project cellular equipment operations. Specifically, the following addresses daily noise production and exposure associated with operation of the project emergency generator and outdoor equipment cabinets.

Please refer to Appendix A for definitions of acoustical terminology used in this report. Appendix B illustrates common noise levels associated with various sources.


## Criteria for Acceptable Noise Exposure

### Santa Cruz County General Plan Noise Element

The Santa Cruz County General Plan Noise Element provides regulations regarding noise levels produced by stationary (non-transportation) noise sources. The primary objective of the Noise Element is to prescribe policies that lead to the preservation and enhancement of the quality of life for the residents of Santa Cruz County by securing and maintaining an environment free from hazardous and annoying noise. These standards are summarized below in Table 1.

<b>Table 1</b> <b>Maximum Allowable Noise Exposure for Stationary Noise Sources</b> <b>Santa Cruz County Noise Element of the General Plan</b>		
<b>Noise Level Descriptor</b>	<b>Daytime</b> <b>7 a.m. to 10 p.m.</b>	<b>Nighttime</b> <b>10 p.m. to 7 a.m.</b>
Hourly $L_{eq}$ , dB	50	45
Maximum Level ( $L_{max}$ ), dB	70	65
Source: Santa Cruz County Noise Element of the General Plan		

**Figure 1**  
**Project Area and Nearest Noise-Sensitive Receivers**  
**North Summit Cellular Facility - Santa Cruz County, California**





### **Santa Cruz County Code**

Section 13.10.663 of the Santa Cruz County Code states that backup generators shall only be operated during power outages and for testing and maintenance purposes. If the facility is located within 100 feet of a residential dwelling unit, noise attenuation measures shall be included to reduce noise levels at the facility to a maximum exterior noise level of 60 dB  $L_{dn}$  at the property line and a maximum interior noise level of 45  $L_{dn}$  within the nearby residence.

As shown in Figure 1, the proposed cellular facility is located approximately 360 feet away from the nearest residence. Because the proposed cellular facility would be located over 100 feet away from the nearest residence, the noise level criteria presented in Section 13.10.663 of the Santa Cruz County Code would not be applicable to this project. However, the project noise emissions would still be required to comply with the County of Santa Cruz General Plan Noise Element noise level criteria, presented previously in Table 1.

### **Discussion of Noise Standard Interpretation Relative to Cellular Facility Projects**

Both the County General Plan Noise Element and Noise Ordinance apply the County's noise standards at the property line of the noise-sensitive receiving use. In cases where there are residences located in close proximity to the property lines, application of the noise standards at the project property lines ensures that adequate protection will be in place to ensure the residents are not adversely affected by noise.

Cellular projects are different than most noise-generating projects in that the cellular companies make efforts to locate their proposed equipment as far away from residences as practical, including the residence on the property being leased for the cellular equipment. The result is frequently that the cellular equipment is located far from residences but very close to residential property lines.

The high-frequency noise generated by cellular equipment cabinet cooling fans (the only source of noise associated with the equipment cabinets), dissipates rapidly over distance. As a result, if equipment cabinets are located adjacent to a property line, it's not uncommon for the fan noise to exceed property line noise standards even though the noise has dissipated rapidly within 50 to 100 feet from the cabinets. In addition, cellular cabinet fans frequently cycle off when temperatures drop during nighttime hours and cooling requirements are greatly diminished.

The other noise source associated with cellular projects is the emergency generator. The generator's function is to maintain communications during power outages. As a result, the only time the generator operates is during relatively infrequent power outages and for a period of 15 minutes during daytime hours twice a month to ensure the generator will be functional should a power outage occur.

With a level 2 acoustic enclosure, a typical cellular facility generator emits a noise level of 68 dB at a reference distance of 23 feet. If the generator is located within 10 feet of a residential property line, a condition which is not uncommon, the noise level while operating is approximately 75 dB at that property line. A level of 75 dB will exceed most nighttime property line noise standards even though the nearest residences may be hundreds of feet away and there is no noise-sensitivity at the property line.

Because the noise generation of outdoor equipment cabinet fans is low and dissipates rapidly, and because cellular facility generators would only operate during nighttime hours to maintain vital communications during power outages, it is BAC's professional opinion that noise impacts associated with cellular facilities are more appropriately evaluated in the immediate vicinity of residences rather than at property lines. In addition, because cellular facility generators operate for extended periods at night only during emergency power outages, the noise created by emergency generator operations would appropriately be exempted from local noise provisions. Finally, it is BAC's professional opinion that noise generated during routine, twice-monthly, daytime generator testing should be evaluated relative to local daytime maximum noise level standards.

BAC does not dictate noise policy, or interpretation of noise policy, to city or county planning departments. As a result, this analysis assesses noise impacts at residential property lines as required by the local noise standards. However, noise impacts are also evaluated in the immediate vicinity of existing residences where the actual noise sensitivity is greatest. The preceding discussion is provided to encourage planning departments to consider latitude in interpreting their noise standards in cases where cellular facilities are proposed near residential property lines but considerable distances from the nearest residences.

## Project Noise Generation

As discussed previously, there are two project noise sources which are considered in this evaluation; the equipment cabinet cooling systems and the emergency generator. The evaluation of potential noise impacts associated with the operation of each noise source is evaluated separately as follows:

### Equipment Cabinet Noise Sources and Reference Noise Levels

The project proposes the installation of four equipment cabinets within the lease area illustrated on Figure 1. Specifically, the cabinets assumed for the project are as follows: two Ericsson eNB RBS6101, one Charles Industries 48V Power Plant and one miscellaneous cabinet cooled by a McLean Model T-20 air conditioner. The cabinets and their respective reference noise levels are provided below in Table 2. The manufacturer's noise level data specification sheets for the proposed equipment cabinets are provided as Appendix C.

<b>Table 2</b> <b>Reference Noise Level Data of Proposed Equipment Cabinets</b>			
<b>Equipment</b>	<b>Number of Cabinets</b>	<b>Reference Noise Level, dB</b>	<b>Reference Distance, feet</b>
Ericsson eNB RBS6101	2	53	5
Charles Industries 48V Power Plant	1	60	5
McLean T-20	1	66	5
Notes: Manufacturer specification sheets provided as Appendix C.			

### Generator Noise Sources and Reference Noise Levels

A Generac Industrial Power Systems Model SD030 is proposed for use at this facility to maintain cellular service during emergency power outages. The site plans indicate that the generator, located within the same lease area as the equipment cabinets, will be equipped with the Level 2 Acoustic Enclosure resulting in a reference noise level of 68 dB at 23 feet. The manufacturer's noise level data specification sheet for the proposed generator is provided as Appendix D.

The generator which is proposed at this site would only operate during emergencies (power outages) and brief daytime periods for periodic maintenance/lubrication. According to the project applicant, testing of the generator would occur twice per month, during daytime hours, for a duration of approximately 15 minutes. The emergency generator would only operate at night during power outages.

### Predicted Facility Noise Levels at Nearby Sensitive Receptors

As indicated in Figure 1, the cellular facility maintains a separation of 360-470 feet from the nearest existing residences, identified as receivers 1-3. The residence identified as receiver 3 is located within the same parcel as the proposed facility (APN: 098-021-06). The nearest off-site residence is identified as receiver 2 on Figure 1. In addition, the nearest property line containing a residence (receiver 1) is located approximately 260 feet north of the proposed project equipment.

Assuming standard spherical spreading loss (-6 dB per doubling of distance), project-equipment noise exposure at the closest receivers was calculated and the results of those calculations are presented in Table 3.

<b>Table 3</b> <b>Summary of Project-Related Noise Exposure at Nearest Residences and Property Line</b> <b>North Summit Verizon Wireless Telecommunications Facility Project</b>			
Nearest Receiver <sup>1</sup>	Distance from Cellular Equipment (feet)	Predicted Noise Levels (dBA)	
		Outdoor Cabinets <sup>2</sup>	Generator
1	470	28	42
2	430	28	43
3	360	30	44
Property Line	260	33	47
Notes:			
<sup>1</sup> Receiver locations are shown on Figure 1.			
<sup>2</sup> The four equipment cabinets were conservatively assumed to be in operation concurrently.			

#### Outdoor Equipment Cabinet Noise Assessment

Because the proposed outdoor equipment cabinets could potentially be in operation during nighttime hours, the operation of the equipment cabinets would be subject to the County's hourly average nighttime noise level standard of 45 dB  $L_{eq}$ . As indicated in Table 3, predicted outdoor equipment noise levels of 28-30 dB  $L_{eq}$  at the nearest existing residences would satisfy the Santa Cruz County 45 dB  $L_{eq}$  nighttime noise level standard. In addition, at the nearest residential property line to the northwest, predicted outdoor equipment noise levels of 33 dB  $L_{eq}$  would also satisfy the County's nighttime noise level standard. As a result, no further consideration of noise mitigation measures would be warranted for this aspect of the project.

#### Generator Noise Assessment Relative to County's Daytime Maximum (70 dB $L_{max}$ ) Standard

Because the project generator would only operate during daytime hours for brief periods required for testing and maintenance, and assuming generator noise would be considered exempt during emergency operations, noise from the generator could be subject to the County's maximum daytime noise level standard of 70 dB  $L_{max}$ . As indicated in Table 3, predicted generator noise levels of 42-44 dB  $L_{max}$  would satisfy the Santa Cruz County maximum daytime noise level standard of 70 dB  $L_{max}$ . In addition, at the nearest residential property line to the northwest, predicted generator noise levels of 47 dB  $L_{max}$  would also satisfy the County's daytime noise level standard. As a result, no additional noise mitigation measures would be warranted for this aspect of the project if the County's maximum daytime noise standard is applicable.

### Generator Noise Assessment Relative to County's Nighttime Average (45 dB $L_{eq}$ ) Standard

The County has indicated that they prefer generator noise be assessed relative to their nighttime average noise level standard of 45 dB  $L_{eq}$ . As shown in Table 3, the predicted generator noise levels of 42-44 dB  $L_{eq}$  at the nearest residences would satisfy the Santa Cruz County average nighttime noise level standard of 45 dB  $L_{eq}$ . However, at the nearest property line to the northwest, predicted generator noise levels of 47 dB  $L_{eq}$  would exceed the County's nighttime criteria. A discussion of potential mitigation measures to meet the County's property line noise level standard can be found in the mitigation section of this report.

## Impacts at Property Line and Associated Mitigation

The proposed project equipment is located approximately 260 feet south of the nearest residential property line. As discussed previously, application of the County's noise level standards at the nearest property line would result in an exceedance of the Santa Cruz County General Plan noise level standards.

### Generator Mitigation

If the County applies the property line hourly average nighttime noise level standard of 45 dB  $L_{eq}$  to the proposed generator, mitigation would be required. To mitigate this identified exceedance to a state of compliance with the County's noise level standard, the effectiveness of constructing a noise barrier was considered. The project site plans indicate the construction of a 6-foot tall wood fence along the lease area perimeter. The wood fence would provide the necessary generator noise attenuation provided the slats overlap by a minimum of 2 inches and are screwed into the framing. The purpose of overlapping slats and using screws rather than nails is to ensure that prolonged exposure to the elements does not result in visible gaps through the slats which would result in reduced noise barrier effectiveness. A 6-foot tall wood fence with overlapping slats would reduce project generator noise exposure to 41 dB  $L_{eq}$  at the nearest property line. An 8-foot tall wood fence with overlapping slats would reduce project generator noise exposure to 38 dB  $L_{eq}$  at the nearest property line. Both fence heights would reduce project generator noise to a state of compliance with the Santa Cruz County noise level standards.



## Conclusions

### Predicted Noise Levels at Residences

Based on the equipment noise level data and analyses presented above, project-related equipment noise exposure is expected to satisfy the recommended interpretation of the Santa Cruz County noise exposure limits at the closest residential receivers. Specifically, the proposed outdoor equipment cabinets would be in compliance with the nighttime 45 dB  $L_{eq}$  noise level standard and the generator (Generac SD030 equipped with level 2 acoustic enclosure) would be in compliance with the daytime 70 dB  $L_{max}$  noise level standard. As a result, no additional consideration of noise mitigation measures would be warranted for the project.

### Predicted Noise Levels at Nearest Property Line

Project-related equipment noise exposure is expected to satisfy the Santa Cruz County nighttime 45 dB  $L_{eq}$  noise level standard at the nearest property line provided that the proposed lease area perimeter wood fence slats overlap by a minimum of 2 inches and that the slats are screwed to the framing rather than nailed. Predicted generator noise levels at the nearest property line would be 41 dB  $L_{eq}$  and 38 dB  $L_{eq}$  with 6 and 8-foot wood fence heights, respectively.

This concludes our environmental noise assessment for the proposed North Summit Cellular Facility in Santa Cruz County, California. Please contact BAC at (916) 663-0500 or [paulb@bacnoise.com](mailto:paulb@bacnoise.com) with any questions or requests for additional information.


## Appendix A Acoustical Terminology

<b>Acoustics</b>	The science of sound.
<b>Ambient Noise</b>	The distinctive acoustical characteristics of a given space consisting of all noise sources audible at that location. In many cases, the term ambient is used to describe an existing or pre-project condition such as the setting in an environmental noise study.
<b>Attenuation</b>	The reduction of an acoustic signal.
<b>A-Weighting</b>	A frequency-response adjustment of a sound level meter that conditions the output signal to approximate human response.
<b>Decibel or dB</b>	Fundamental unit of sound, A Bell is defined as the logarithm of the ratio of the sound pressure squared over the reference pressure squared. A Decibel is one-tenth of a Bell.
<b>CNEL</b>	Community Noise Equivalent Level. Defined as the 24-hour average noise level with noise occurring during evening hours (7 - 10 p.m.) weighted by a factor of three and nighttime hours weighted by a factor of 10 prior to averaging.
<b>Frequency</b>	The measure of the rapidity of alterations of a periodic signal, expressed in cycles per second or hertz.
<b>L<sub>dn</sub></b>	Day/Night Average Sound Level. Similar to CNEL but with no evening weighting.
<b>Leq</b>	Equivalent or energy-averaged sound level.
<b>L<sub>max</sub></b>	The highest root-mean-square (RMS) sound level measured over a given period of time.
<b>Loudness</b>	A subjective term for the sensation of the magnitude of sound.
<b>Masking</b>	The amount (or the process) by which the threshold of audibility for one sound is raised by the presence of another (masking) sound.
<b>Noise</b>	Unwanted sound.
<b>Peak Noise</b>	The level corresponding to the highest (not RMS) sound pressure measured over a given period of time. This term is often confused with the Maximum level, which is the highest RMS level.
<b>RT<sub>60</sub></b>	The time it takes reverberant sound to decay by 60 dB once the source has been removed.
<b>Sabin</b>	The unit of sound absorption. One square foot of material absorbing 100% of incident sound has an absorption of 1 sabin.
<b>SEL</b>	A rating, in decibels, of a discrete event, such as an aircraft flyover or train passby, that compresses the total sound energy of the event into a 1-s time period.
<b>Threshold of Hearing</b>	The lowest sound that can be perceived by the human auditory system, generally considered to be 0 dB for persons with perfect hearing.
<b>Threshold of Pain</b>	Approximately 120 dB above the threshold of hearing.




## Appendix B

### Typical A-Weighted Sound Levels of Common Noise Sources Decibel Scale (dBA)\*



## Appendix C-1



**WEIGHT WITH BATTERIES:**  
2296 LBS.

NorthStar NSB-170FT batteries  
at 128 lbs each, Qty 12

**WEIGHT WITHOUT BATTERIES:**  
760 LBS.

**MAX NOISE LEVEL:**  
55-60dB

**CHARLES PART #**  
**CUBE-SS4C215XC1**




Charles Industries Ltd.  
Telecommunications Group  
Charles Center, 5600 Apollo Drive  
Bellingham, WA 98226  
Telephone: 847-806-6380

THIS IS THE PROPERTY OF CHARLES INDUSTRIES LTD. AND SHALL NOT BE  
REPRODUCED, COPIED OR USED IN ANY MANNER DETRIMENTAL TO THEIR INTERESTS.


**Verizon Wireless**  
**Large Site Support Enclosure**



## Appendix C-2



## Appendix C-2



# Appendix D


GENERAC<sup>®</sup> INDUSTRIAL  
POWER

## SD030

## dimensions, weights and sound levels



30 kW Diesel

5 of 5





### OPEN SET

RUN TIME HOURS	USABLE CAPACITY (GAL)	L	W	H	WT	dBA*
NO TANK	-	76	38	45	2060	82
20	54	76	38	59	2540	
48	132	76	38	71	2770	
77	211	76	38	83	2979	
109	300	93	38	87	3042	





### STANDARD ENCLOSURE

RUN TIME HOURS	USABLE CAPACITY (GAL)	L	W	H	WT	dBA*
NO TANK	-	95	38	50	2362	77
20	54	95	38	63	2842	
48	132	95	38	75	3072	
77	211	95	38	87	3281	
109	300	95	38	91	3344	



### LEVEL 1 ACOUSTIC ENCLOSURE

RUN TIME HOURS	USABLE CAPACITY (GAL)	L	W	H	WT	dBA*
NO TANK	-	113	38	50	2515	70
20	54	113	38	63	2995	
48	132	113	38	75	3225	
77	211	113	38	87	3434	
109	300	113	38	91	3497	



### LEVEL 2 ACOUSTIC ENCLOSURE

RUN TIME HOURS	USABLE CAPACITY (GAL)	L	W	H	WT	dBA*
NO TANK	-	95	38	62	2520	68
20	54	95	38	75	3000	
48	132	95	38	87	3290	
77	211	95	38	99	3439	
109	300	95	38	103	3502	

\*All measurements are approximate and for estimation purposes only. Weights are without fuel in tank. Sound levels measured at 23ft (7m) and does not account for ambient site conditions.

- Tank Options**
- ☐ MDEQ OPT
  - ☐ Florida DERM/DEP OPT
  - ☐ Chicago Fire Code OPT
  - ☐ IFC Certification CALL
  - ☐ ULC CALL
- Other Custom Options Available from your  
Generac Industrial Power Dealer

### YOUR FACTORY RECOGNIZED GENERAC INDUSTRIAL DEALER

Specification characteristics may change without notice. Dimensions and weights are for preliminary purposes only. Please consult a Generac Power Systems Industrial Dealer for detailed installation drawings.

Generac Power Systems, Inc. • S45 W29290 HWY. 59, Waukesha, WI 53189 • generac.com

© 2012 Generac Power Systems, Inc. All rights reserved. All specifications are subject to change without notice. Bulletin 01950105BY-B / Printed in U.S.A. 02/15/12